

2531-CPR-CX010121

1. Unique identification code of product-type:

PP

EN

2. Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 21-0051 : See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Penetration Seals, See ETA 21-0051

Cable Penetrations	Insulated & non insulated & cables	The field of application has to comply with the content of ETA 21-0051
Pipe Penetrations	Non insulated metal conduits	The field of application has to comply with the content of ETA 21-0051

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:


ETA Danmark issued European technical approval - ETA 21-0051 on the basis of EAD 350454-00-1104 Fire Stopping and Fire Sealing Products & issued certificate of conformity 2531-CPR-CXO10121

9. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	NPD
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 21-0051 clause 3.2 - Annex C
Dangerous Substances	See ETA 21-0051 Clause 3.5
Service & Durability	Type Y1:intended for use at temperatures below 0°C with exposure to UV but no exposure to rain in accordance with EOTA technical documents TR024
Airborne Sound Insulation	See ETA 21-0051 Annex B

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



..... 20/07/2021

L.Peach - Technical Director



..... 20/07/2021

M.Metcalfe - Firestop Manager